

9/1/25



SANITAATION CERTIFICATE

Certified that the sanitary facilities of AL-FALAH
AMM ENGLISH SCHOOL

Alancode, Malappuram is owned by
CHARMAN AL-FALAH Amm Educational Trust
Kakkidippuram Alancode, Malappuram is adequately hygienic and
environmentally good. This certificate is issued to produce at
Alancode Grama panchayath for getting license only.

The validity period of this certificate is only from 3.6.2025
to 31.3.2026 or up to the date on which the public
health authority finds that the place is unhealthy or insanitary
whichever is earlier.

This is for the CBSE affiliation renewal



Alancode

Date: 3.6.2025

[Signature]

MANAGER

AL-FALAH AMM ENGLISH SCHOOL
KAKKIDIPPURAM, ALANKODE.P.O
PIN:679585

[Signature]

Health Inspector
FHC Alancode

HEALTH INSPECTOR
PRIMARY HEALTH CENTRE

ALANKODE

P.O. NANNAMMUKKU-679 579



GeoMax

Water Quality Analysis Lab

(Kerala Govt. PCB approved)

Approval No: PCB/CL/RL/96 A/2021

IG Arcade | Near Alankar Theater | CV junction
Ponnani | Malappuram Dt | Kerala 679577 | Office: 0494 2663333
geomaxlab@gmail.com | www.geomaxlab.com
Mob: 9946376606 | 8547663388 | 83019222

REPORT ON ANALYSIS OF WATER

Name & Address : AL FALAH ENGLISH SCHOOL-KAKKIDIPPURAM
Source of sample : **FILTER UNIT** (SAMPLE COLLECTED & BROUGHT BY PARTY)
Date of Collection : 17/05/2025
Date of Testing : 17/05/2025


Reference No: GM/13796

Sl No.	Characteristics	Unit	Method	Desirable limits	Actual Contents
1	Turbidity	NTU	IS 10500/Part10	1	0.1
2	Colour	Hazen	IS 10500/Part 4	5	1
3	Odour		IS 10500/Part 5	-	Agreeable
4	P ^H Value		IS 10500/Part11	6.50 -8.50	6.42
5	Electrical Conductivity	µs/cm			50.07
6	Total Dissolved Solids (TDS)	mg/litre	IS 10500/Part16	500	28.54
7	Acidity	mg/litre	IS 10500/Part22	-	25.0
8	Alkalinity(Total)	mg/litre	IS 10500/Part23	200	23.5
9	Total Hardness(as CaCO ₃)	mg/litre	IS 10500/Part21	200	10.0
10	Calcium	mg/litre	IS 10500/Part40	75	2.0
11	Magnesium	mg/litre	IS 10500/Part46	30	1.21
12	Chloride	mg/litre	IS 10500/Part32	250	9.86
13	Iron	mg/litre	IS 10500/Part53	1	0.012
14	Sulphate	mg/litre	IS 10500/Part24	200	BDL
15	Ammonia	mg/litre	IS 10500/Part34	0.5	BDL
16	Residual, free chlorine	mg/litre	IS 10500/Part26	0.2	BDL
Microbiological Parameters					
17	Total Coliform	MPN/100ml	IS 1622	0	0
18	E-Coli	No Of	IS 1622	Absent/100	ABSENT

Remarks: pH value is within the desirable limit.

BDL: BELOW DETECT

BDL: BELOW DETECT



MANAGER
AL-FALAH AMM ENGLISH SCHOOL
KAKKIDIPPURAM, ALANKODE, P.O.
PIN: 679585

Other tested parameters are



Signature of chemist
Signature of micro biologist