

9/1/25



SANITAATION CERTIFICATE

Certified that the sanitary facilities of AL-FALAH
AMM ENGLISH SCHOOL

Alancode, Malappuram is owned by
CHAIRMAN AL-FALAH AMM Educational Trust
Kakkidippuram

Alancode, Malappuram is adequately hygienic and environmentally good. This certificate is issued to produce at Alancode Grama panchayath for getting license only.

The validity period of this certificate is only from 3.6.2025
to 31.3.2026 or up to the date on which the public health authority finds that the place is unhealthy or insanitary whichever is earlier.

This is for the CBSE affiliation renewal

Alancode

Date : 3.6.2025

Principal

AL FALAH A.M.M. ENGLISH SCHOOL (AMES)

Affiliated to CBSE. No: 930983

Kakkidippuram - Alankode(PO), Malappuram Dt.

Kerala - Pin :679585



Health Inspector

FHC Alancode

HEALTH INSPECTOR

PRIMARY HEALTH CENTRE

ALANKODE

P.O. NANNAMMUKKU-679 575

MANAGER

AL-FALAH AMM ENGLISH SCHOOL

KAKKIDIPURAM, ALANKODE.P.O

PIN:679585



GeoMax

Water Quality Analysis Lab

(Kerala Govt. PCB approved)

Approval No: PCB/CL/RL/96 A/2021

IG Arcade | Near Alankar Theater | CV junction
Ponnani | Malappuram Dt | Kerala 679577 | Office: 0494 266333

geomaxlab@gmail.com | www.geomaxlab.com

Mob: 9946376606 | 8547663388 | 83019229

REPORT ON ANALYSIS OF WATER

Name & Address : AL FALAH ENGLISH SCHOOL-KAKKIDIPPURAM
Source of sample : **FILTER UNIT** (SAMPLE COLLECTED & BROUGHT BY PARTY)
Date of Collection : 17/05/2025
Date of Testing : 17/05/2025

Reference No: GM/13796

Sl No.	Characteristics	Unit	Method	Desirable limits	Actual Contents
1	Turbidity	NTU	IS 10500/Part10	1	0.1
2	Colour	Hazen	IS 10500/Part 4	5	1
3	Odour		IS 10500/Part 5	-	Agreeable
4	P ^H Value		IS 10500/Part11	6.50 –8.50	6.42
5	Electrical Conductivity	µs/cm			50.07
6	Total Dissolved Solids (TDS)	mg/litre	IS 10500/Part16	500	28.54
7	Acidity	mg/litre	IS 10500/Part22	-	25.0
8	Alkalinity(Total)	mg/litre	IS 10500/Part23	200	23.5
9	Total Hardness(as CaCO ₃)	mg/litre	IS 10500/Part21	200	10.0
10	Calcium	mg/litre	IS 10500/Part40	75	2.0
11	Magnesium	mg/litre	IS 10500/Part46	30	1.21
12	Chloride	mg/litre	IS 10500/Part32	250	9.86
13	Iron	mg/litre	IS 10500/Part53	1	0.012
14	Sulphate	mg/litre	IS 10500/Part24	200	BDL
15	Ammonia	mg/litre	IS 10500/Part34	0.5	BDL
16	Residual, free chlorine	mg/litre	IS 10500/Part26	0.2	BDL
Microbiological Parameters					
17	Total Coliform	MPN/100ml	IS 1622	0	0
18	E-Coli	No Of colonies/100ml-	IS 1622	Absent/100	ABSENT

Remarks: pH value is low, use proper technique to increase pH. Other tested parameters are within the desirable limit.

BDL: BELOW DETECTION LEVEL

Principal
AL FALAH A.M.M. ENGLISH SCHOOL (AMES)
Affiliated to CBSE. No: 930983
Kakkidippuram - Alamkode(PO), Malappuram Dt.
Kerala - Pin :679585



MANAGER
AL-FALAH AMM ENGLISH SCHOOL
KAKKIDIPPURAM, ALANKODE P.O.
PIN: 679585

Signature of micro biologist